

FINAL ANALYSIS REPORT

5 October 2016

Nu-Age Plaster NZ
 Factory Road, Waharoa
 PO Box 195, Matamata

Date Received: 4/10/16
Lab Number: 78444
Order Number/Ref: Lab
Date Completed: 5/10/16
Temperature: N/A

Attention: Mike James



Henry Cao
 Authorised Signatory
 On behalf of SGS New Zealand Ltd

The Results of analysis on the sample/s as received from Nu-Age Plaster NZ and described below, are as follows.
 The Sample/s were received in good condition. Analysis of the sample/s commenced on 4/10/2016

D	Sample Description	Chloride in Concrete % BS 1881 Part 124 1988
1	Structural Mortar	0.02
2	Jet Black Mortar	<0.01
3	P White Mortar	<0.01
4	Grey Mortar	<0.01

Legend: < = less than limit of detection, > = greater than, [ND] = not detected, TNTC = too numerous to count

END OF REPORT

This document is issued by the Company under its General Conditions of Service accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.